



Fosroc Inc.
Construction Division

55 Skyline Drive
Plainview, NY 11803
Tel 516-935-9100
Fax 516-935-9143

November 21, 1994

Mr. Paul Betty
Coverdeck Systems
440 Copper Drive
Newport Industrial Park
Newport, DL 19804

Dear Mr. Betty:

After reviewing the samples of the "Coverdeck System" which you forwarded to Fosroc, it is our impression that it will not affect the performance of our "Dekguard system" protective coating.

Furthermore it will not void Fosroc warranties that are now in force.

We recommend a cure time for the "Dekguard system" of 28 days prior to the placement of "Coverdeck" on top.

If you have further questions, please contact me.

Sincerely,

A handwritten signature in cursive script that reads "Dawn Diamond".

Dawn Diamond
Northeast Regional Manager