

# Sika Corporation

## Construction

October 1, 2010

Coverdeck Systems, Inc.  
305 East Ayre Street  
Newport, DE 19804

Attn: Mr. Paul Betty  
Fax: 302-427-7582

Re: Coverdeck System / Sikalastic Traffic System

Dear Mr. Betty,

Upon review of information and samples provided, for the Coverdeck System, it is Sika's opinion that the Coverdeck would be compatible to properly applied and fully cured, Sikalastic Traffic Systems.

Some key installation factors/conditions for placement of the covering over the Sika system would include:

1. No mechanical fasteners being used.
2. No assemblies that could jeopardize the integrity of the Sikalastic system (no sharp objects).
3. Proper drainage exists to prevent moisture entrapment.

Therefore, Sika would stand behind a properly installed and fully cured, Sikalastic system, provided it was not compromised by a covering/topping or its installation procedures.

Regards,



Tom Zuppa  
Sr. Technical Service Manager  
Construction Division

cc: Joe Vullo-Sika Corporation  
Wayne Ellis-Sika Corporation



Sika Corporation, 201 Polito Avenue, Lyndhurst NJ 07071, USA  
Tel: 201 933 8800, Fax: 201 933 6225, [www.sikausa.com](http://www.sikausa.com)

