

Tremco Incorporated
3735 Green Road, Beachwood, OH 44122 Tel: 216-292-5000 FAX: 216-766-8843

TREMCO

Sealant/Weatherproofing Division
Tremco • Mameco/VULKEM® • Paramount

FAX LETTER: 302-427-7582

Coverdeck Systems
1704 Shallcross Avenue
Wilmington, DE 19806

Attn: Mr. Paul Betty, President

Re: Coverdeck Interlocking Modular Carpet System


Dear Mr. Betty;

I have examined the sample of "Coverdeck" you submitted for our evaluation as to its installation over Vulkem 350/351 pedestrian deck waterproofing system. The information you supplied suggests this is a "loose-laid, interlocked" system.

"Coverdeck" will have no effect on the Vulkem 350/351 installation so long as the following criteria for installation are met:

- 1) The Vulkem 350/351 system must have cured completely before the "Coverdeck" is installed. A 28 day cure period is recommended.
- 2) No fasteners which penetrate the Vulkem 350/351 system are used for installing the "Coverdeck" system. The use of adhesives is permitted over the Vulkem 351 topcoat.

Very truly yours,



Wesley K. Senseman
Director Technical Services
Sealants & Weatherproofing

c: M. Soeder
E. Horstman,
TechServ